
घी के लिए तलछट टंकी — विशिष्टि

(पहला पुनरीक्षण)

Settling Tanks for Ghee — Specification

(First Revision)

ICS 67.260

© BIS 2018



भारतीय मानक ब्यूरो

BUREAU OF INDIAN STANDARDS

मानक भवन, 9 बहादुरशाह ज़फर मार्ग, नई दिल्ली-110002

MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI-110002

www.bis.org.in www.standardsbis.in

FOREWORD

This Indian Standard (First Revision) was adopted by the Bureau of Indian Standards, after the draft finalized by the Dairy Products and Equipment Sectional Committee had been approved by the Food and Agriculture Division Council.

Settling tanks for *ghee* are used in the *ghee* refineries and dairies to remove non-fatty solid residues from *ghee* by allowing the heated *ghee* to stand. This standard would help the fabricator and the user to obtain quality equipment meeting the desired mechanical and hygienic requirements.

Settling tanks for *ghee* may be of the following four types:

- a) Single-walled;
- b) Double-walled (single jacketed) with a provision for circulation of water or steam or both;
- c) Double-jacketed, insulated with a provision for circulation of water or steam or both in the inner jacket; and
- d) Double-walled, insulated.

This standard was first published in 1968. This revision is being undertaken to cover the requirements for only double-walled (single jacketed) cylindrical settling tanks for *ghee*, as they are most commonly used. Also the sizes of tanks widely used in *ghee* manufacturing have been selected in this standard. The nominal capacities as recommended in IS 2843 : 1964 'Recommendations on nominal capacities for process equipment' have been adopted in sizing the settling tanks.

This standard includes the requirements for cylindrical tanks only since cylindrical tanks with conical bottoms are comparatively less costly as compared with rectangular tanks as the cost of the material and fabrication would be less. This standard is intended chiefly to cover the technical provisions relating to jacketed stainless steel *ghee* settling tank, and it does not include all the necessary provisions of a contract.

The word 'stainless steel' appearing at various places in this standard shall mean ISS 304 (equivalent to AISI 304) stainless steel conforming to designation X04Cr19Ni9 of IS 6911 : 1992 'Stainless steel plate, sheet and strip — Specification (*first revision*)'. Only Stainless Steel Tungsten Inert Gas (TIG) Arc Welding using AWS ER 316L filler metal conforming to IS 2811 : 1987 'Recommendations for manual tungsten inert-gas arc welding of austenitic stainless steel (*first revision*)' shall be done for all joints in stainless steel sheet.

For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test shall be rounded off in accordance with IS 2 : 1960 'Rules for rounding off numerical values (*revised*)'. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

Indian Standard

SETTLING TANKS FOR *GHEE* — SPECIFICATION

(*First Revision*)

1 SCOPE

This standard prescribes the important constructional details and dimensional requirements for double-walled (single jacketed) stainless steel settling tanks (vertical cylindrical) for *ghee*.

2 REFERENCES

The standards given below contain provisions which, through reference in this text, constitute provisions of this standard. At the time of publication, the editions indicated were valid. All standards are subject to revision and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent editions of these standards.

<i>IS No.</i>	<i>Title</i>
2811 : 1987	Recommendations for manual tungsten inert-gas arc welding of austenitic stainless steel (<i>first revision</i>)
3178 : 1996	Abrasive emery grain — Specification
3382 : 1965	Specification for stainless steel milk pipes and fittings
6911 : 1992	Stainless steel plate, sheet and strip — Specification (<i>first revision</i>)

3 CAPACITY

3.1 The tanks shall be constructed in capacities of 500, 1 000, 2 000 and 3 000 litres.

3.1.1 The capacity is a rounded off value of the calculated capacity of the container which includes the volume of the bottom but does not include the volume of branches/nozzles.

4 MATERIAL

4.1 All the component metallic parts of tanks, which come into contact with the *ghee*, and the cover shall be constructed from stainless steel conforming to steel grade designation ISS 304 having Cr 18-20 percent and Ni 8-10 percent as per IS 6911. The weld areas and the deposited material shall be as corrosion resistant as the parent material.

4.2 Non-metallic material may be used for sealing, but such material shall be non-toxic, corrosion resistant, relatively non-absorbent and shall not impart any objectionable odour or flavour and dissolve in the *ghee* or cleaning solutions or bactericidal agents normally used.

4.3 Outer jacket and all such parts of the surfaces of the *ghee* settling tank, which do not come into contact with the *ghee*, shall also be made of steel grade designation ISS 304.

5 SHAPE AND DIMENSIONS

5.1 The cylindrical settling tanks of 500, 1 000, and 2 000 litres capacities shall be with conical bottom (10°) and half openable three piece covers on top. The centre portion of the cover should be fixed type. The leading dimensions of vertical cylindrical tanks shall be as given in Table 1 (*see also* Fig. 1).

6 THICKNESS OF MATERIAL

The minimum thickness of the material for tanks and cover shall be as given in Table 2.

7 FABRICATION

7.1 The typical designs of the settling tanks for *ghee* of different capacities are shown in Fig.1.

Table 1 Dimensions of Vertical Cylindrical Settling Tanks for *Ghee*
(*Clause 5.1 and Fig. 1*)

Capacity	Inner Diameter	Outer Diameter	Cylindrical Body Straight Height	Distance Between Legs (cc)	Height of Leg
litres	mm	mm	mm	mm	mm
(1)	(2)	(3)	(4)	(5)	(6)
500	900	1 060	860	634	1 317
1 000	1 200	1 360	1 000	848	1 317
2 000	1 400	1 560	1 415	990	1 357
3 000	1 600	1 760	1 620	1 134	1 357

Table 2 Thickness of Material for Cylindrical Tanks
(Clause 6)

Capacity litres	Inner Shell mm	Outer Shell mm	Conical Bottom mm	Outer Bottom mm	Openable Cover mm
(1)	(2)	(3)	(4)	(5)	(6)
500	2.0	2.0	2.0	2.0	2.0
1 000	2.0	2.0	2.5	2.0	2.0
2 000	2.0	2.0	2.5	2.0	2.0
3 000	2.0	2.0	3.0	2.0	2.0

7.2 All joints which come into contact with *ghee* shall be butt welded and finished smooth by buffing with IS Grit No. 220 (*see* IS3178).

7.3 All surfaces, which come into contact with *ghee*, shall be free from crevices and finished smooth. All inside corners shall have a radius of not less than 25 mm.

7.4 All component parts and appurtenances having surfaces in contact with *ghee* shall be easily removable for cleaning or shall be readily cleanable in their places.

7.5 The tank shall be so constructed that it will not sag, buckle or prevent complete drainage.

7.6 Stainless steel flat of suitable cross-section shall be welded at the brim of the tanks from outside to strengthen the tank top edge.

8 SUPPORTS (LEGS)

8.1 The tanks shall be supported on stainless steel (AISI 304) legs (four numbers for tanks upto 2 000 litres and 6 for tanks of 3 000 litres) and welded over doubling pads provided on the bottom of tank's inner body. The pads shall be of stainless steel. The legs shall be of SS pipe of diameter 50 mm for tanks of capacity 500 litres and 1 000 litres and of diameter 65 mm for tanks of capacity 2 000 litres and 3 000 litres.

8.2 The legs shall have adjustable stainless steel ball feet with provision for height adjustment upto 50 mm, as shown in Fig. 1.

9 COVER

Three pieces cover with a fixed central portion made of 4 mm thick stainless steel and two loose removable pieces with lifting handles made from 2 mm thick stainless steel shall be provided as shown in Fig. 1.

10 INLET

10.1 A vertical removable type stainless steel no foam inlet pipe connection terminating with a complete stainless steel union of 38 mm (*see* IS3382) shall be provided on the top of the tanks as shown in Fig. 1.

10.2 Air Vent

A stainless steel air vent of size 51 mm for tanks upto 1 000 litres and of size 65 mm for 2 000 and 3 000 litres tanks shall be provided on top of the tank. The vent shall have sufficient free opening area (with wire mesh cover fitted) to prevent formation of partial vacuum during cleaning in place / emptying and pressure build up during filling of the tank. The vent shall be protected from ingress of vermin / insects by removable wire mesh cover. The vent shall also be protected by a hood to prevent any dirt or other particles falling from above. The hood should be bolted down.

11 OUTLET

11.1 Bottom

A 50.8 mm diameter vertical outlet with stainless steel straight through plug type flanged valve ending in complete stainless steel union (*see* IS 3282) shall be provided at the centre of bottom conical portion. This outlet should be at a height of 650 mm from the finished floor level to facilitate placement of can under it.

11.2 Side



A 50.8 mm diameter horizontal outlet with stainless steel angular flanged valve ending in complete stainless steel union (*see* IS 3382) shall be so located on the straight cylindrical body that the distance between the centre line of the outlet and the line joining conical bottom to cylindrical body is 100 mm.

11.3 The outlet shall project to at least 75 mm from the tank body.

12 SPRINKLER

12.1 Sprinkler Pipe

Sprinkler pipe of 25 mm diameter made from stainless steel shall be provided for sprinkling hot water or chilled water on the outer surface of inner shell. The sprinkler pipe shall have adequate numbers of stainless union on equal space to make it completely removable. The sprinkler pipe shall end outside in a header with two separate connections for hot and chilled water.



DIMENSION TABLE											
Cap.	D	D1	D2	D3	D4	R1	R2	C/C	H	H1	H2
500 L	900	1 060	25φ	51 φ	50 φ	500	400	634	860	150	1 317
1 000 L	1 200	1 360	25φ	51 φ	50 φ	500	400	848	1 000	150	1 317
2 000 L	1 400	1 560	38φ	76 φ	65 φ	600	500	990	1 415	190	1 357
3 000 L	1 600	1 760	48φ	76 φ	65 φ	700	600	1 134	1 620	215	1 357

FIG. 1 JACKETED GHEE SETTLING TANK (CYLINDRICAL)
(CAPACITY 500, 1 000, 2 000 AND 3 000 LTR)

12.2 Drain

A stainless steel drain of 38 mm diameter with Gun Metal valve shall be located at the bottom of the jacket (outer shell).

12.3 U-Bend

Stainless steel U-bend of diameter 38 mm shall be located at the bottom of the jacket for maintaining water level inside the jacket.

12.4 Steam Ejector

Stainless steel steam ejector/steam sparger shall be located near the bottom of the jacket for heating *ghee* inside the tank. The connection should end outside in a flange and counter flange. The ejector has to be removable type.

12.5 Over Flow

Stainless steel overflow pipe of diameter 38 mm shall be located in the upper portion (below the sprinkler header) of the jacket as shown in Fig. 1.

13 DRAIN

13.1 A vertical drain connection for cylindrical tanks and horizontal drain connection for rectangular tanks shall be located on the lowest part of the bottom.

13.2 The drain shall be of a minimum size of 50.8 mm terminating with a 50.8 mm male part (*see* IS 3382).

13.3 The drain shall project to 75 mm from the bottom of the jacket.

14 LEAKAGE TESTS

14.1 The inner shell of the tank shall be tested for water

tightness in the manufacturer's works after grinding and polishing the surfaces. The tank fitted with stoppers for side and bottom outlets shall not leak when filled with water upto the brim.

14.2 Water fill-up test of jacket for water tightness after grinding and polishing the surfaces. The jacket fitted with stopper for its drain shall not leak when filled with water upto the overflow.

14.3 Dye penetration test shall be conducted for all welding joints of inner shell to ensure no defect.

15 MARKING

15.1 Each settling tank shall be provided with a stainless steel nameplate of size 150 mm × 100 mm fixed on a stainless steel bracket. Following particulars shall be indelibly and legibly marked on the name plate:

- a) Manufacturer's trade-mark, name and address;
- b) Manufacturer's identification;
- c) Capacity of the tank; and
- d) Month and year of manufacturing.

15.2 BIS Certification Marking

Each tank may also be marked with the BIS Standard Mark.

15.2.1 The use of the Standard Mark is governed by the provisions of the *Bureau of Indian Standards Act, 2016* and the Rules and Regulations made thereunder. The details of conditions under which the licence for the use of the Standard Mark may be granted to manufacturers or producers may be obtained from the Bureau of Indian Standards.

Bureau of Indian Standards

BIS is a statutory institution established under the *Bureau of Indian Standards Act*, 2016 to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

Copyright

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publications), BIS.

Review of Indian Standards

Amendments are issued to standards as the need arises on the basis of comments. Standards are also reviewed periodically; a standard along with amendments is reaffirmed when such review indicates that no changes are needed; if the review indicates that changes are needed, it is taken up for revision. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition by referring to the latest issue of 'BIS Catalogue' and 'Standards : Monthly Additions'.

This Indian Standard has been developed from Doc No.: FAD 19 (2675).

Amendments Issued Since Publication

Amend No.	Date of Issue	Text Affected

BUREAU OF INDIAN STANDARDS

Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002

Telephones : 2323 0131, 2323 3375, 2323 9402

Website: www.bis.org.in

Regional Offices:

	Telephones
Central : Manak Bhavan, 9 Bahadur Shah Zafar Marg NEW DELHI 110002	{ 2323 7617 2323 3841
Eastern : 1/14 C.I.T. Scheme VII M, V. I. P. Road, Kankurgachi KOLKATA 700054	{ 2337 8499, 2337 8561 2337 8626, 2337 9120
Northern : Plot No. 4-A, Sector 27-B, Madhya Marg, CHANDIGARH 160019	{ 26 50206 265 0290
Southern : C.I.T. Campus, IV Cross Road, CHENNAI 600113	{ 2254 1216, 2254 1442 2254 2519, 2254 2315
Western : Manakalaya, E9 MIDC, Marol, Andheri (East) MUMBAI 400093	{ 2832 9295, 2832 7858 2832 7891, 2832 7892

Branches: AHMEDABAD. BENGALURU. BHOPAL. BHUBANESHWAR. COIMBATORE. DEHRADUN. DURGAPUR. FARIDABAD. GHAZIABAD. GUWAHATI. HYDERABAD. JAIPUR. JAMMU. JAMSHEDPUR. KOCHI. LUCKNOW. NAGPUR. PARWANOO. PATNA. PUNE. RAIPUR. RAJKOT. VISAKHAPATNAM.

Published by BIS, New Delhi